

Equipment Inspection Checklist

Project Name:
Checklist No.
Make:
OWN

Hired

Project Code:
Date:
Model:
Contractor

Equipment Name & Number:		CONCRETE PUMP		
Note: Please write Yes or No in the given box and if some comments write in remarks column.				
SN.	Description		Yes/No	Remarks
1.	Concrete pump should be physically in good condition.	#		
2.	No damage in tire (Bolts, crack, cuts & air pressure, etc.).	#		
3.	Outrigger should be free from damages.	#		
4.	Dangerous or moving part should be covered with fix guard.	#		
5.	Panel/switch board should be covered properly.			
6.	Emergency stop button should be mushroom headed with red color.	#		
7.	Concrete hopper should be in good condition.			
8.	Suitable mesh should be kept on hopper to avoid getting in touch with moving part.	#		
9.	Clamp should be proper for tight joint of pipe.	#		
10.	Hook should have sufficient strength to carry self-load during shifting.			
11.	In case of electrically operated, electrical connection should be taken in proper manner.	#		
12.	In case of electrically operated, machine should be grounded as per IS 3043:1987.	#		
13.	Concrete pump should be operated by competent person, with valid license and TPC.	#		
14.	Concrete pipe should be free from damages.	#		



FIT	<input type="checkbox"/>	PARTIALLY FIT	<input type="checkbox"/>	UNFIT	<input type="checkbox"/>
Inspected By		Reviewed By			
Name:		Name:			
Signature with date:		Signature with date:			