


Equipment Inspection Checklist

Project Name:
Checklist No.
Make:
OWN

Hired

Project Code:
Date:
Model:
Contractor

Equipment Name & Number:		ELECTRICAL PUMP/MOTOR		
Note: Please write Yes or No in the given box and if some comments write in remarks column.				
SN.	Description		Yes/No	Remarks
1.	Physical condition of pump should be good.	#		
2.	Power cable should be free from damages and connection taken through industrial plug.	#		
3.	Cable entry point should be fully packed, so that water can't enter.	#		
4.	Junction box of motor should be free from defects.	#		
5.	On/off switch should be properly insulated.	#		
6.	Rotating part of machine should be covered by fixed guard.	#		
7.	Machine should be grounded as per IS 3043:1987.	#		
8.	Work carried out by competent person with TPC			



FIT	<input type="checkbox"/>	PARTIALLY FIT	<input type="checkbox"/>	UNFIT	<input type="checkbox"/>
Inspected By		Reviewed By			
Name:		Name:			
Signature with date:		Signature with date:			