


Equipment Inspection Checklist

Project Name:
Checklist No.
Make:
 OWN

Hired

Project Code:
Date:
Model:
 Contractor

Equipment Name & Number:		POWER/SUB DISTRIBUTION PANEL		
Note: Please write Yes or No in the given box and if some comments write in remarks column.				
SN.	Description		Yes/No	Remarks
1.	Physical condition of panel should be good & sound.	#		
2.	Panel should be kept on suitable stand.	#		
3.	Junction boxes should be free from defects.	#		
4.	All connection should be taken through ELCB/RCCB/MCB.	#		
5.	Connection socket should be covered with auto lock.			
6.	Switches and display should be properly covered.			
7.	A danger signage should be marked.			
8.	Panel should be grounded as per IS 3043:1987.	#		
9.	Further connection for extension of cable should be taken through male-female connector.	#		
10.	In case of flammable atmosphere single length cable shall be use.			
11.	Canopy should be provided to avoid water getting entered due to rain or any other means.	#		
12.	Rubber mat should be provided to stand during operation.	#		
13.	Input power cable should be free from defects.			
14.	Work carried out by competent person with TPC			
15.	Power input and output cable should be passes through glands.	#		



FIT	<input type="checkbox"/>	PARTIALLY FIT	<input type="checkbox"/>	UNFIT	<input type="checkbox"/>
Inspected By			Reviewed By		
Name:			Name:		
Signature with date:			Signature with date:		